

ANALYTICAL TEST CERTIFICATE



PRIVATE AND CONFIDENTIAL

Salvador Olvera
Water Purification Limited
St. Martins House Business Centre, Ockham Rd S,
East Horsley, Leatherhead Surrey
United Kingdom
GB
KT24 6RX

Sample Date: 28/05/2025
Sample Time: 12:00
Date received and analysis started: 29/05/2025

Site: Coldharbour Cricket Club
Sampled by: Adam
Sample Point: Shower (New System)

Unique Lab Ref No: 273604

RESULTS OF ANALYSIS

	Theoretical Lower Limit of Detection		Number Isolated
Legionella culture (GAMC01, GAMC10)	25 cfu / vol analysed		Not Detected / 250 ml

COMMENTS

The results are acceptable. Consult the attached decision matrix for information on relevant legislation and guidance.
All GAMC Methods used are documented in section C of the Feedwater Ltd General Analytical Method manual. Copies are available on request.
Signed:

Devin Hemmings
Microbiology Laboratory Supervisor

Date: 09/06/2025

*Tests marked * are not included in the UKAS accreditation scheme for this Laboratory. Any comments, interpretation, recommendation and opinions given in this report are not part of the analytical results and are not part of the UKAS accreditation scheme for this Laboratory. They are offered merely to assist in the interpretation of the results. Sampling is not included in our accreditation. These results relate solely to the sample under test. We do not take into account uncertainty when reporting results.*

This report should not be reproduced in whole or in part without the written authority of Feedwater Ltd.
Specialising in: Chemical Water Treatments, Control Equipment, Cleaning and Disinfection, Risk Assessments
and Diagnostic Sampling for prevention of Legionnaires Disease.
Registered Office: As above. Registered in England. Registered No. 1274270.

www.feedwater.co.uk